



National Centre for Radio Astrophysics
TATA INSTITUTE OF FUNDAMENTAL RESEARCH

NCRA, PUNE UNIVERSITY CAMPUS, POST BAG 3, GANESHKHIND, PUNE 411 007, INDIA
Telephone off. Purchase +91 20 2571 9266 / 9206 / 9205; General + 91 20 2571 9000, 2571 9111
Fax (general) +91 20 25692149; Gram RASTRON; E-mail : purchase@ncra.tifr.res.in

PUBLIC TENDER FOR CONSTRUCTION OF MULTIPURPOSE
BUILDING AT GMRT, KHODAD

TENDER NO NCRA/WF178/PUB341/2013

MINUTES OF THE PRE-BID MEETING ON Friday, 04 April, 2014 AT NCRA,
Pune AT 3.00PM

1. The bidders need not have registration with CPWD/PWD/MES/RAILWAYS Dcsem etc but must have work experience and financial capability as mentioned in the "Eligibility Criteria".
2. No electricity shall be provided by Client to the contractor or for the labour camp. Temporary electrical connection for construction purpose will have to be obtained at their cost by the contractor who will be executing the job .
3. Space for labour camp, across the site , shall be provided by the client . Contractor shall have to make arrangements for the water, electricity and conservancy at the camp.
4. Site concrete with Mix Design (from agencies like Duracrete) is acceptable.
5. Minimum site welding is expected for the roof trusses etc. which should be prefabricated in parts and brought to site. Any welding has be done after obtaining clearance from the client.
6. Basic rates for Cement and steel is not given in the tender document as no escalation in cost shall be allowed.
7. Bidders shall quote rates without taxes. The taxes (VAT & Service Tax) shall be added to the grand total at the end. The percentage of taxes shall also be mentioned clearly in the covering letter to be submitted in the "Techno-commercial Bid" without fail .

Contd...2

Giant Metrewave Radio Telescope (GMRT), Khodad. A National Project of the Government of India

Bu



National Centre for Radio Astrophysics

TATA INSTITUTE OF FUNDAMENTAL RESEARCH

Pune.

Continuation Sheet

-2-

8. All the bills are to be addressed to “GMRT, office Khodad.” and hence No LBT shall be paid by the client .
9. Use of mobiles is not allowed at the site . Care should be taken by the contractor that the mobiles are not used by the labour in the camp.
10. Borewell may be drilled by the contractor at the site at his own cost and risk, with prior approval from the client regarding the location. Water may be used for the construction, if found suitable.
11. One BSNL landline connection and one intercom connection shall be provided by the client and charges as applicable will have to be paid by the contractor.

Above points will form an integral part of the tender document and bidders will have to submit this sheet (with their signature and seal as a token of acceptance of these conditions)with the tehnocommercial bid (part1 of tender) without fail..

The above minutes is also posted on our website www.ncra.tifr.res.in

Bn Nagarimbh
10/4/2014