



Government eProcurement System		eProcurement System Government of India			
Published Corrigendum Details					
		Date : 09-Jun-2026 12:18 PM			
		 Print			
Organisation Chain :	Department of Atomic Energy Tata Institute of Fundamental Research-Colaba-Mumbai-Purchase Dept-TIFR-DAE NCRA(Pune)-TIFR-DAE				
Tender ID :	2026_DAE_910250_1				
Tender Ref No :	NCRA WF022 CPPP 2026-27				
Tender Title :	Providing and laying cement concrete road for approach to N12 and S12 tower and near stone quarter at RAC Ooty.				
Corrigendum Type :	Other				
Corrigendum Document Details					
Corr.No.	Corrigendum Title	Corrigendum Description	Published Date	Document Name	Doc Size(in KB)
1	Replies to Pre-bid queries	Clarifications with respect to pre-bid meeting.	09-Jun-2026 12:18 PM	MOM.pdf 	56.68



NCRA • TIFR

राष्ट्रीय रेडियो खगोलभौतिकी केंद्र
National Centre for Radio Astrophysics
टाटा मूलभूत अनुसंधान संस्थान
Tata Institute of Fundamental Research

गणेशखिंद डाकघर, सावित्रीबाई फुले पुणे विश्वविद्यालय परिसर, पुणे - 411007, महाराष्ट्र. दूरभाष : 020-2571-9000-9111
Ganeshkhind PO, Savitribai Phule Pune University Campus, Pune -411007, Maharashtra, Phone: 020-2571-9000-9111
ई-मेल / E.mail : purchase@ncra.tifr.res.in वेबसाइट/Website: www.ncra.tifr.res.in

Minutes of the Meeting (MOM)

08.06.2026

Sub : Minutes of the pre-bid meeting held on 08.06.2026 from 11.30 am to 12.10 pm online (through Google Meet) and offline (at RAC, Ooty).

Tender Name:- Providing and laying cement concrete road for approach to N12 and S12 tower and near stone quarter at RAC Ooty.

Tender Ref. No. - NCRA:WF022:CPPP:2026-27

Tender CPPP Id :- 2026_DAE_910250_1

In reference to the above tender a Pre bid meeting was scheduled and accordingly held today (08.06.2026) in hybrid mode (through google meet) and offline (at RAC , Ooty)

Following bidders attended the meeting:

1. M/s Kashyap Constructions , Pune (through google meet) -9823105050-kashyapconstruction@gmail.com
2. M/s Kalbhreshwara Enterprises, Bangalore (through google meet)-9845889979-c.raj77@gmail.com
3. M/s P. Murlidharan , Ooty (in offline Mode at RAC)-9600850236-devasurya51@gmail.com

Following NCRA/RAC Officials attended the meeting:

1. Shri Abhishek Prasad- Engineer-D (Civil)
2. Shri S. D. Patil - Group Head (Civil)
3. Shri S. M. Kulkarni - Administrative Officer (B)

In the meeting the following queries were raised by the contractor and the their reply given are as under:

4. Query: Sh. Charan of M/s Kalbhreshwara Enterprises, Bangalore informed that in Ooty there is no RMC plant available. The nearest RMC plant is either in Mettuaplayam (~50 Km) or in Gudalur (~50 Km) . He requested to allow Self-Loading Concrete Mixer (SLCM) popularly known as Ajax Machine.

Reply: Self-Loading Concrete Mixer (SLCM) popularly known as Ajax Machine may be allowed subjected to the adherence of the following criteria:

- Proper design mix should be done from approved Lab and subsequently to be vetted by NCRA officials.
- Necessary materials for the concrete should be properly stored at site & proper vehicle movement over the existing road by taking necessary precautions.

Contd...2

Minutes of the Meeting (MOM)

08.06.2026

- In site, the contractor must ensure that the concrete laid is as per the approved design mix.
- Minimum 25-30 cum of concrete should be poured in a day.
- Cube test should be done as per the provision of IS code and reports should be submitted at RAC, Ooty.

5. Query : Sh. Kashyap of M/S Kashyap Enterprises, Pune informed that since no RMC plant is available in Ooty , he requested to allow weigh batcher Concrete Mixer / Self-Loading Concrete Mixer (SLCM)

Reply: weigh batcher Concrete Mixer may also be allowed subjected to the adherence of the following criteria:

- Proper design mix should be done from approved Lab and subsequently to be vetted by NCRA officials.
- Necessary materials for the concrete should be properly stored at site & proper vehicle movement over the existing road by taking necessary precautions.
- In site, the contractor must ensure that the concrete laid is as per the approved design mix.
- Minimum 25-30 cum of concrete should be poured in a day.
- Cube test should be done as per the provision of IS code and reports should be submitted at RAC, Ooty.

6. Query: Sh. Kashyap of M/S Kashyap Enterprises, Pune asked about the tentative schedule date to start the work.

Reply: The tentative schedule to start the work is in the first week of September 2026 (subjected to weather condition of ooty) or from First week of January 2027

With the above, meeting concluded.

Sd/-

Administrative Officer-C (P&S)